



Reg. No. 041/P-007

NOTIFIED BODY 1396
Osloboditeľ'ov 282, 059 35 Batizovce, Slovakia
Tel.+421 52 285 1611, www.fires.sk



Certificate of constancy of performance

1396-CPR-0218

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction products Regulation or CPR), this certificate applies to the construction product

Circular fire damper FDR-3G

used to prevent fire and reduce smoke spreading from one fire compartment to another through the air ductwork system which may penetrate fire separating walls and floors. In the case of fire or elevated temperatures, the dampers close automatically by means contained within their own construction. The product used on conditions defined in Assessment and verification of constancy of performance C1396/21/0025/4002/SC (issued by FIRES, s.r.o., NB 1396 on 20. 06. 2022) is

placed on the market under the name or trade mark of the manufacturer

**KOOLAIR DIFUSION DE AIRE SL
C/Urano 26, 28936 Móstoles, Madrid, Spain**

and produced in the manufacturing plants

**SAFEAIR SL
Avda San Isidro Nave C-3 S/N, 45223 Seseña, Toledo, Spain**

**Systemair Production a.s.
Hlavná 371, 900 43 Kalinkovo, Slovak Republic.**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 15650: 2010

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on 20. 06. 2022 and will remain valid as long as neither the harmonized standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Batizovce 20. 06. 2022



Ing. Henrieta Lapková
Head of Product Certification Body

139536

FIRES 136a/C-31/01/2017-E