

CERTIFICATE OF CONSTANCY OF PERFORMANCE

LGAI Technological Center, S.A. (APPLUS)
Notified Body Nr. 0370

No.

0370-CPR-1687

In compliance with Regulation (EU) Nr. 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

SMOKE AND HEAT CONTROL SYSTEMS. SMOKE CONTROL DAMPERS.

MODEL: **CEVH**

Placed on the market under the name of:

SAFEAIR, S.L. (GRUPO KOOLAIR)

POL. IND. SAN ISIDRO
AVDA. SAN ISIDRO NAVE C-3
45223 SESEÑA (TOLEDO) SPAIN

And produced in the manufacturing plant:

POL. IND. SAN ISIDRO
AVDA. SAN ISIDRO NAVE C-3
45223 SESEÑA (TOLEDO) SPAIN

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

EN 12101-8:2011

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 11th April 2014 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body. It is confirmed on 25th October 2024.

The monitoring assessment will be done before 31st October 2025

Bellaterra, 25th October 2024


LGAI Technological Center, S.A.

Xavier Ruiz Peña
Managing Director, Product Conformity B.U.



This document is not valid without its technical annex; whose number coincides with that of the certificate.

You can check the validity of this certificate on our website: www.appluslaboratories.com/certified_products

The manufacturer, after the completion of the conformity assessment procedures and the declaration of performance, may affix the CE Marking under his responsibility

0370-CPR-1687

Annex according to **EN 12101-8:2011**

SMOKE AND HEAT CONTROL SYSTEMS. PART 8: SMOKE CONTROL DAMPERS.

CERTIFIED PERFORMANCES

Essential characteristics	Clauses in this European Standard	Mandated level(s) or class(es)
Nominal activation conditions/sensitivity	4.2.1.3	PASS
Response delay (response time)	4.2.1.4	PASS
Operational reliability	4.3.2.2	300 Cycles
Fire resistance – Integrity	4.1.1 a), 4.4.1	EI 120 (Ved i ↔ o) S 1500 AA multi
Fire resistance – Insulation	4.1.1 b), 4.4.1	EI 120 (Ved i ↔ o) S 1500 AA multi
Fire resistance – Smoke leakage	4.1.1 c), 4.4.1	EI 120 (Ved i ↔ o) S 1500 AA multi
Fire resistance – Mechanical stability (under E)	4.1.1 d)	EI 120 (Ved i ↔ o) S 1500 AA multi
Fire resistance – Maintenance of the cross section (under E)	4.1.1 e)	EI 120 (Ved i ↔ o) S 1500 AA multi
Fire resistance – High operational temperature	4.1.1 f), 4.4.1	NA
Durability of response delay	4.4.2.1	PASS
Durability of operational reliability	4.4.2.2	PASS

PASS; NPD = No Performance Determined; NA = Not Applicable

PRODUCT

- Smoke control damper of double blade with automatic activation.
- Dimensions rectangular wall range 1100x1100 mm up 400x400 mm. t
- Tested at 300 cycles.
- EI 120 (Ved i ↔ o) S 1500 AA multi.
- Manual closing mechanism and coil spring opening mechanism.
- The Smoke damper is held in closed position by coil Thermal class B
- The damper is tested in vertical duct made in plates thick 52 mm that crosses the slab.
- Fire Test pressure -500 Pa and environmental temperature- 1500 Pa
- Accessories:
 - Metallic pre-frame, sealing duct by fire resistant mastic

Complete technical data related to the certified range of products is detailed in the technical file and in the range report 13/5709-3063