

# CERTIFICATE OF CONSTANCY OF PERFORMANCE

LGAI Technological Center, S.A. (APPLUS)  
Notified Body Nr. 0370

No. **0370-CPR-3851**

In compliance with Regulation (EU) Nr. 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

## VENTILATION FOR BUILDINGS. FIRE DAMPERS

MODEL: **SCFR-3H**

Placed on the market under the name of:

## **SAFEAIR, S.L. (GRUPO KOOLAIR)**

POL. IND. SAN ISIDRO  
AVDA. SAN ISIDRO NAVE C-3  
45223 SESEÑA (TOLEDO) SPAIN

And produced in the manufacturing plant:

POL. IND. SAN ISIDRO  
AVDA. SAN ISIDRO NAVE C-3  
45223 SESEÑA (TOLEDO) SPAIN

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

### **EN 15650:2010**

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 26<sup>th</sup> June 2020 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body. It is confirmed on 25<sup>th</sup> October 2024.

### **The monitoring assessment will be done before 31<sup>st</sup> October 2025**

Bellaterra, 25<sup>th</sup> October 2024

  
LGAI Technological Center, S.A.

Xavier Ruiz Peña  
Managing Director, Product Conformity B.U.

*This document is not valid without its technical annex; whose number coincides with that of the certificate.*

*You can check the validity of this certificate on our website: [www.appluslaboratories.com/certified\\_products](http://www.appluslaboratories.com/certified_products)*



The manufacturer, after the completion of the conformity assessment procedures and the declaration of performance, may affix the CE Marking under his responsibility

## 0370-CPR-3851

Annex according to **EN 15650:2010**

### VENTILATION FOR BUILDINGS. FIRE DAMPERS

#### CERTIFIED PERFORMANCES

Essential characteristics	Clauses in this European Standard	Mandated level(s) or class(es)
Nominal activation conditions/sensitivity: - Sensing element load bearing capacity - Sensing element response temperature	4.2.1.2 4.2.1.2.2 4.2.1.2.3	PASS
Response delay (response time): - Closure time	4.2.2.2	PASS
Operational reliability: - Cycling	4.3.1, a)	50 Cycles
Fire resistance:		
- Integrity	4.1.1, a)	EI 180 ve i ↔ o) S
- Insulation	4.1.1, b)	EI 180 ve i ↔ o) S
- Smoke leakage	4.1.1, c)	EI 180 ve i ↔ o) S
- Mechanical stability (under E)	4.1.1, a)	EI 180 ve i ↔ o) S
- Maintenance of the cross section (under E)	4.1.1, a)	EI 180 ve i ↔ o) S
Durability of response delay: - Sensing element response to temperature and load bearing capacity	4.2.1.2.2 4.2.1.2.3	PASS
Durability of operational reliability: - Open and closing cycle tests	4.3.3.2	10.000 Cycles (motorized) 300 Cycles (manual)

PASS; NPD = No Performance Determined; NA = Not Applicable

#### PRODUCT

- Single blade fire damper, SCFR-3H.
- Rectangular range dimensions from 1500x800 mm to 200x200 mm for rigid wall.
- Damper tested on a rigid wall (vertical mounted).
- 50 open/close cycles before testing.
- Test pressure 500 Pa.
- Rigid Wall installation options:
  - Manual TH70 trigger mechanism and manual reset. Automatic closure with spring and Elsie fuse Mfg type B 70°C;
  - Manual TH70 trigger mechanism or remote control by coil and manual reset;
  - Manual TH70 trigger mechanism or remote control by coil and motorized reset. Manual operation TH70 Elsie fuse Mfg type B 70°C, remote control with coil and reset Belimo BL24-48KO;
  - GGA326.1E/KA of Siemens reset mechanism with thermal fuse 72°C;
  - Belimo BFN230-T reset mechanism with thermal fuse 72°C

The complete technical data of the certified range **SCFR-3H** are detailed in the technical file and the range report nº 20/21626-44, 20/20966-930 and 20/21626-44-1.